

Certificate of Conformance - AS/NZS 4020: 2018

Page 1 of 1

CoC no: ABC50861

Date Issued: 31/03/2023

Eurofins Sample No: NJ22AB4589-1

Expiry Date: 30/03/2028

Contracted Company: Eurofins ams Laboratories (Sydney)

Address: 179 Magowar Road, Girraween, NSW 2145 Australia

Licence no: TGA Licence No: MI-2021-LI-08995-1 APVMA Licence No: 6241

Client Information

Company Name: EBRO Armaturen Pacific Pty Ltd

Client Acc No: A01485050K41

Company Address: 2/6 Northumberland Road, Caringbah, NSW 2229, Australia

Standard Information

Standard: AS/NZS 4020:2018

Description: Testing of products for use in contact with drinking water

Product Information

Product: EBRO Butterfly Valve Series

Model: Z011-A, Z011-B, Z014-A, Z014-B, F012-A, F012-K1

Range: 50mm to 2000mm

A sample product from the above model and range was supplied by **EBRO Armaturen Pacific Pty Ltd** on **16/12/2022** for compliance testing to AS/NZS 4020:2018, Testing of products for use in contact with drinking water.

All tests were conducted on the samples provided and all tests were completed and evaluated on **31/03/2023**. Detailed Report Certificate of Analysis ref. no.: **NJ22AB4589-1**.

Compliance Description:

Based on completion and evaluation of tests on 31/03/2023, the product: EBRO Butterfly Valve Series, Model: Z011-A, Z011-B, Z014-A, Z014-B, F012-A, F012-K1, Range: 50mm to 2000mm; fully complied with the test requirements of AS/NZS 4020:2018 to cover a cold water application up to 40°C, at the recommended 'in-the-product' exposure with a scaling factor of 0.1 (1/10) applied at $(20 \pm 2)^{\circ}\text{C}$.