



AGA CERTIFIED PRODUCT

Certificate Holder: **EBRO ARMATUREN PACIFIC PTY LTD**

ABN/ACN No. (if applicable): **82 090 475 951**

Manufacturer: **Ebro Armaturen, GmbH, Germany**

Agent (if applicable): **N/A**

Type of Component: **Manual Butterfly Valves**

Model No. & Description: **EBRO ARMATUREN**

(Refer www.aga.asn.au for more details)

Wafer Pattern Butterfly Valve TYPE Z 011-A, PN-16
Lug Type Butterfly Valve TYPE Z 014-A, PN-16
Size range: DN40, DN50, DN65, DN80, DN100, DN125, DN150

Type 1 Isolating valves
Maximum working pressure: 1600kPa
Operating temperature range: -10°C to +90°C

Relevant Standard(s): **AS4617-2018 (Inc. Amend. No. 1)**



This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.





Client Manager



Certificate Authorised

Certificate first issued: **8 December 2021**

Certificate No: **8995**

This copy valid from: **8 December 2021**

Refer specification issue: **01**